

How this sheet works: the subcontractor ticks and initials each point as the work is checked. ONE named reviewer — the principal contractor's site manager or quality manager — releases every HOLD POINT on this sheet, all the way to completion. The client, contract administrator or clerk of works signs once, at the end. A stack of these signed at a desk is not evidence — every hold point needs a reading, a photo reference and a date. Issue with the activity RAMS.

1 WHERE — A STRANGER MUST BE ABLE TO FIND THIS AREA FROM THIS SHEET IN FIVE YEARS

BLOCK / BUILDING	LEVEL / FLOOR	SYSTEM / BUILDING	GRIDLINES	DRAWING AND REVISION
PROJECT / SITE REF	SITE	SPEC CLAUSE / SCHEDULE	SUBCONTRACTOR INSPECTOR	REVIEWER — RELEASES THE HOLD POINTS

2 THE SPECIFIED SYSTEM — FROM THE SPECIFICATION AND THE DRAWINGS, NOT FROM MEMORY

OUTSTATIONS RELEASED ON KD-QA-BC-001 (REFS)	INTEGRATION SCHEDULE — THIRD-PARTY SYSTEMS AND PROTOCOLS
HEAD END, GRAPHICS AND REMOTE ACCESS SPECIFIED	CLIENT'S OPERATOR (NAME) AND DEMONSTRATION DATE

3. Readiness

HOLD POINT

Every outstation in section 2 released on its KD-QA-BC-001 sheet; every third-party system in section 2 commissioned by its own trade with the certificate reference recorded

CIBSE Code M

Network complete — every device visible at the head end, addresses to the schedule, no communication faults on the log for the period the specification states

Spec

CERTIFICATE REFS OF INTEGRATED SYSTEMS

RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo
SUB SELF-CHECK — INITIALS	DATE	HOLD RELEASED BY THE REVIEWER — SIGNATURE			TIME	DATE

4. Integration tests — witnessed

WITNESS

Every interface on the schedule proved point by point — values read from the third-party system match its own display; commands written to it are seen to act; result recorded per interface

CIBSE Code C · Spec

Alarms from every integrated system reach the head end with the right priority and routing; meter readings at the head end match the meter faces

Spec

Fire alarm interface proved with the fire alarm commissioning (KD-QA-EL-006) — the plant response on the cause-and-effect matrix seen from the head end

Spec

INTERFACES PROVED / ON SCHEDULE	KD-QA-EL-006 REF					
RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo
SUB SELF-CHECK — INITIALS	DATE	WITNESSED BY THE REVIEWER — NAME			DATE	

5. Client demonstration

WITNESS

Whole system demonstrated to the client's operator named in section 2 — graphics, alarms, trends, schedules, set-point changes and overrides — and the operator drives it, not the commissioning engineer

Spec

Trend logs from the period the specification states reviewed with the operator and referenced — the plant has held its set points

Spec

Questions and defects raised at the demonstration listed with the action and date agreed

Practice

DEMONSTRATED TO (NAME) / DATE

TREND LOG REFS / PERIOD

RESULT

Pass

Fail

N/A

NCR REF IF FAIL

PHOTO REF(S)

Date/time on photo

SUB SELF-CHECK — INITIALS

DATE

WITNESSED BY THE REVIEWER — NAME

DATE

6. Records, training and handover

HOLD POINT

O&M manual, as-installed drawings, points schedule, description of operation, software backup, passwords and licences handed to the client's named person; training delivered to the specification's syllabus and recorded

CIBSE Code M · Spec

Commissioning notice for fixed building services prepared for the building control body as the Building Regulations require — reference recorded

Approved Document L

Every snag and non-conformance below closed and re-checked by someone other than the person who fixed it

Practice

HANDOVER DOCUMENT REFS

COMMISSIONING NOTICE REF

RESULT

Pass

Fail

N/A

NCR REF IF FAIL

PHOTO REF(S)

Date/time on photo

SUB SELF-CHECK — INITIALS

DATE

HOLD RELEASED BY THE REVIEWER — SIGNATURE

TIME

DATE

7 SNAGS FOUND IN THIS AREA — MINOR DEFECTS FIXED AND RE-CHECKED ON THE SHEET

A snag is a defect the trade puts right and someone else re-checks. Anything that fails an acceptance criterion outright, or cannot be fixed in the area, is a non-conformance and goes in the next section instead.

NO.	WHERE (ELEMENT / POSITION)	DEFECT FOUND	FIXED BY / DATE	RE-CHECKED BY / DATE...	OK?

8 NON-CONFORMANCES FOR THIS AREA — ONE BLOCK PER NCR; CLOSED BY SOMEONE OTHER THAN THE FIXER

NCR 1 — REFERENCE POINT OWNER (NAMED PERSON) DUE STATUS

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE

RE-INSPECTED BY (NOT THE FIXER) / DATE

PHOTO REF(S)

NCR 2 — REFERENCE POINT OWNER (NAMED PERSON) DUE STATUS

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE

RE-INSPECTED BY (NOT THE FIXER) / DATE

PHOTO REF(S)

NCR 3 — REFERENCE POINT OWNER (NAMED PERSON) DUE STATUS

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE

RE-INSPECTED BY (NOT THE FIXER) / DATE

PHOTO REF(S)

9 PHOTO LOG — WHAT EACH PHOTO REFERENCE SHOWS

PHOTO REF	POINT	WHAT IT SHOWS (LOCATION, ELEMENT, READING VISIBLE)	DATE / TIME	TAKEN BY

10 NOTES FOR THIS AREA

ANYTHING THE NEXT PERSON NEEDS TO KNOW — AGREEMENTS, DEVIATIONS FROM THE SPECIFICATION, ACCESS LIMITS, ITEMS CARRIED TO THE NEXT VISIT

11 RELEASE

The reviewer confirms every hold point on this sheet was released and every snag and non-conformance is closed; the client, contract administrator or clerk of works then signs once. This sheet goes in the handover file with the photos it references.

Subcontractor — work complete and self-checked:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

Reviewer — all hold points released, all snags and non-conformances closed:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

Client / contract administrator / clerk of works — final sign-off:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

R REVISION HISTORY

Every revision of this document, and every review that found nothing to change. The revision on the front of this sheet is the one you are holding — check kubitdocs.com for the current one before use.

Rev	Date	Class	What changed	Authorised by
D0	2026-08-29	first-issue	First issue.	— not yet approved —
A0	2026-08-29	review	Approved for issue by the author. Content unchanged from the draft; the draft status strip is removed. No independent third-party review has been carried out.	Author — director, UK principal contractor, SMSTS. Not an independent review.

Class: first-issue · material (the law, a control, a field or the scope changed — past buyers are notified) · editorial (wording or layout only) · review (checked, nothing changed) · withdrawal. Revision prefix D = draft, not approved and not for sale; A = approved for issue by the person named, on the date shown.