

COSHH ASSESSMENT — DIESEL EXHAUST EMISSIONS

COSHH — SUBSTANCE ASSESSMENT

Plant, generators and delivery vehicles running in enclosed spaces

KD-COSHH-DE-011 Rev A0

COSHH 2002 reg 6: exposure is assessed BEFORE the work starts; reg 7: it is prevented, or adequately controlled, working down the hierarchy — eliminate, substitute, engineer, then RPE last. This assessment covers the substance family below; it is completed against the actual products (their safety data sheets alongside) and the actual task, and briefed to the people exposed. The current workplace exposure limit, where one applies, comes from EH40 and the SDS on the day — write it in below.

1 ASSESSMENT DETAILS

SITE / PROJECT

TASK ASSESSED

PRODUCTS IN USE (SDS TO HAND)

ASSESSED BY

DATE

2 THE SUBSTANCE — WHAT IT IS AND WHAT IT DOES

WHERE IT IS MET: Diesel plant and generators in basements, tunnels, enclosed floors and near air intakes; telehandlers and deliveries idling in loading areas; pumps running under occupied decks.

THE HARM: Diesel exhaust is a known carcinogen. Short term it irritates eyes and airways; the fine particulate goes deep. Enclosed running adds carbon monoxide on top — drowsiness in an enclosed plant area is an emergency, not a nap.

3 EXPOSURE — ROUTES, PEOPLE, LIMIT

Inhalation — dust, fume, vapour or mist

Ingestion — hand to mouth

Skin and eye contact

Others affected — adjacent trades, occupiers, public

WHO IS EXPOSED, HOW LONG, HOW OFTEN

WEL / LIMIT (FROM EH40 AND THE SDS TODAY)

4 CONTROLS — IN THE REG 7 HIERARCHY, ALL IN PLACE BEFORE WORK STARTS

Plan plant out of enclosed spaces: electric plant, or the diesel unit outside with services led in

Where diesel must run enclosed: forced ventilation sized for the plant, exhaust ducted to open air, running time minimised

No-idling rule for vehicles and plant — engines off when not working

Position generators and pumps downwind of work areas and away from building air intakes

CO alarms where enclosed running cannot be avoided; symptoms clear the area first, investigate second

SITE-SPECIFIC CONTROLS FOR THIS TASK

RPE WORN (TYPE, AND FACE-FIT WHERE TIGHT-FITTING)

OTHER PPE FOR THIS SUBSTANCE

5 HEALTH SURVEILLANCE, HYGIENE AND FIRST AID

No routine surveillance; recurring irritation or headaches near plant means the controls have failed — reassess the plant layout.

6 STORAGE, SPILLAGE AND DISPOSAL

Fuel handling under the fuels assessment; DPF and filter cleaning done wet or extracted.

WHERE IT IS STORED ON THIS SITE

SPILL RESPONSE AT THE WORK

7 SIGN-OFF AND BRIEFING

The assessment is complete when the people exposed have been briefed on it. Reassess when the product, task, quantity or location changes — not on an anniversary.

ASSESSOR — PRINTED NAME

SIGNATURE

DATE

WORKFORCE BRIEFED (DATE / RECORD REF)

R REVISION HISTORY

Every revision of this document, and every review that found nothing to change. The revision on the front of this sheet is the one you are holding — check kubitdocs.com for the current one before use.

Rev	Date	Class	What changed	Authorised by
D0	2026-08-31	first-issue	First issue.	— not yet approved —
D1	2026-08-31	material	Actions the internal H&S director review. Lead reframed under CLAW 2002 and ACOP L132 with the COSHH reg 5 disapplication stated and limits prompted from CLAW; the silica harm line corrected to the defensible after-asbestos formulation; titles shortened so the header band prints in full.	— not yet approved —
A0	2026-08-31	review	Approved for issue by the author. Content unchanged from the reviewed draft; the draft status strip is removed. No independent third-party review has been carried out.	Author — director, UK principal contractor, SMSTS. Not an independent review.

Class: first-issue · material (the law, a control, a field or the scope changed — past buyers are notified) · editorial (wording or layout only) · review (checked, nothing changed) · withdrawal. Revision prefix D = draft, not approved and not for sale; A = approved for issue by the person named, on the date shown.