

ELECTRICAL ISOLATION CERTIFICATE

Lock-off and tag-out record — the physical isolation behind a permit

RETAIN WITH THE PERMIT

KD-PTW-EI-011 Rev A0

HSG250 requires isolation certificates as separate documents specifying mechanical, electrical and process isolations. PUWER 1998 reg 19 requires suitable means of isolation from all sources of energy, clearly identifiable and readily accessible, with measures so reconnection does not expose anyone to risk. This certificate is the record of that isolation. It never stands alone — it belongs to a permit.

1 CERTIFICATE IDENTIFICATION

CERTIFICATE NUMBER	LINKED PERMIT NUMBER	PROJECT / SITE REF	LOCATION
SYSTEM ISOLATED		REASON FOR ISOLATION	

2 POINTS OF ISOLATION

POINT OF ISOLATION — BOARD / WAY / DEVI...	TYPE — ELECTRICAL / MECH / P...	METHOD — LOCK / FUSE OUT / LINK OU...	LOCK OR TAG N...	KEY HELD BY

3 PROVING AND SECURING

- Correct equipment positively identified against drawings and labelling
- All sources of supply identified, including standby, UPS, PV, capacitive and stored energy
- Each point locked off with a personal lock, or a multi-lock hasp where more than one party is involved
- Each point tagged with the certificate number, date and name
- Proved dead with an approved voltage indicator, proved live-dead-live
- Earths applied where required, and their positions recorded
- Caution and danger notices posted
- Key custody arrangement agreed and recorded above

TEST INSTRUMENT — TYPE AND SERIAL	PROVING UNIT / KNOWN SOURCE USED	TIME PROVED DEAD

4 ISOLATION APPLIED — ISOLATING AUTHORITY

I certify that the points listed above have been isolated, locked, tagged and proved dead, and that the system is safe for the work described in the linked permit.

PRINTED NAME	APPOINTED ROLE	COMPANY	SIGNATURE	DATE	TIME

5 ISOLATION RECEIVED — PERFORMING AUTHORITY

I have satisfied myself that the isolation described is in place, I have been shown the points of isolation, and I accept the isolation for the work described in the linked permit.

PRINTED NAME	ROLE	COMPANY	SIGNATURE	DATE	TIME

6 DE-ISOLATION AND REMOVAL

I certify that all persons and tools have been withdrawn, all earths applied under this certificate have been removed, all locks and tags removed, and the system is safe to re-energise.

PRINTED NAME	SIGNATURE	DATE	TIME	REGISTER (INITIALS)

Flatten this PDF before archiving so the record cannot be silently edited.

ELECTRICAL ISOLATION CERTIFICATE

continued

RETAIN WITH THE PERMIT

KD-PTW-EI-011 Rev A0

R REVISION HISTORY

Every revision of this document, and every review that found nothing to change. The revision on the front of this sheet is the one you are holding — check kubitdocs.com for the current one before use.

Rev	Date	Class	What changed	Authorised by
D0	2026-08-07	first-issue	First issue.	— not yet approved —
D1	2026-08-10	review	Reviewed - no change to the content. Legislation position reviewed against Product Legislation Register KD-REG-01 Rev R01.3 and the August 2026 horizon scan; cutoff moved to 10 August 2026.	— not yet approved —
A0	2026-08-27	review	Approved for issue by the author. Content unchanged from D1; the draft status strip is removed. No independent third-party review has been carried out.	Author — director, UK principal contractor, SMSTS. Not an independent review.

Class: first-issue · material (the law, a control, a field or the scope changed — past buyers are notified) · editorial (wording or layout only) · review (checked, nothing changed) · withdrawal. Revision prefix D = draft, not approved and not for sale; A = approved for issue by the person named, on the date shown.