

Statutory basis: HSWA 1974 s.2(2)(a) and MHSWR 1999 regs 3 and 5; Work at Height Regulations 2005; Manual Handling Operations Regulations 1992; COSHH 2002 with EH40/2005 (4th edition, 2020) — wet cement is corrosive and a potent sensitiser, and resin systems sensitise on skin contact; PUWER 1998 for pumps and mixers; CDM 2015 regs 13 and 15. Where the render forms part of an external wall build-up on a relevant building, the materials are governed by Building Regulations 2010 reg 7(2) and the specification is not a matter for site — a render coat is not substituted to suit availability.

1 DOCUMENT AND PROJECT IDENTIFICATION

RAMS REFERENCE	PROJECT / SITE REF	SITE NAME AND ADDRESS	DATE PREPARED	NEXT REVIEW DATE
CLIENT / PRINCIPAL CONTRACTOR	PLANNED START	DURATION	OPERATIVES	SUPERVISING THE WORK

2 SCOPE OF WORKS

Machine application of external render: pump set-up and hose runs, spray application of base and finish coats, and ruling and finishing behind the spray.

This document does not cover: the insulation layer of an EWI system, scaffold erection and alteration, and pump maintenance beyond the daily checks.

SITE-SPECIFIC SCOPE, LOCATIONS AND LIMITATIONS

3 RISK ASSESSMENT — SCORE EACH RISK FOR THIS SITE, THEN ADD WHAT IS MISSING

The hazards and controls below are the starting point for this activity, written by a working main contractor. They are not complete for your site until a competent person has scored each risk, added the site-specific hazards, and struck out anything that does not apply. Rate risks High / Medium / Low before and after controls.

1. Render pump pressure, hoses and blockages

At risk: Operatives, anyone on the hose route

Controls: Pump operated by a trained operative only. Hoses inspected and coupled with safety pins and whip checks before start; the route is walked and anyone working along it is briefed. The line is depressurised and confirmed at zero before any coupling is broken, and a blockage is cleared to the manufacturer's procedure — never by striking the line, never by looking into the nozzle.

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

2. Wet cement and render — burns and sensitisation

At risk: Operatives

Controls: Wet cement is corrosive and a potent skin sensitiser, and cement burns develop slowly enough that people do not notice them happening. Waterproof gauntlets and waterproof knee protection are not optional; splashes are washed off immediately, not at the end of the day; nobody kneels or stands in wet render. Washing facilities are at the workplace. Any operative with an existing skin condition is assessed before starting.

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

3. Overloading the scaffold with materials, or rendering through a tied bay

At risk: Operatives, everyone below

Controls: The scaffold loading class is confirmed before any material is landed, and stacked materials are kept within it and spread — a pallet of render on one bay is a point load. Ties are NEVER removed to render behind them without the scaffold contractor doing it under their own procedure and re-tying immediately. Boards and edge protection are checked before each shift and after any adjustment; the current scaffold inspection tag is checked before the crew goes up.

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

4. Work at height from steps, podiums, towers or MEWPs

At risk: Operatives, and anyone below

Controls: Select access by the Work at Height hierarchy — podium or tower before steps; MEWPs by trained (IPAF) operators only. Inspect access equipment before use, establish an exclusion below overhead work, and secure tools and materials against dropping.

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

5. Noise from cutting, fixing and plant

At risk: Operatives, others in the area

Controls: Select quieter methods and tools where practicable; hearing protection in designated zones and for noisy operations; agree noisy-works windows with the occupier in occupied buildings.

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

6. Interface with occupants, other trades and the public

At risk: Occupants, other trades, the public

Controls: Segregate the work area — barriers, signage, sheeting; agree access routes and working hours with the occupier; never obstruct escape routes; deliveries and waste runs outside peak movement times where agreed.

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

7. Manual handling of boards, materials and components

At risk: Operatives

Controls: Mechanical aids first — trolleys, board lifters, hoists. Two-person lifts for boards and long components; order materials in manageable sizes; plan storage close to the workforce; keep carrying routes clear and lit.

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

Site-specific hazards not listed above — every site has at least one:

HAZARD	WHO IS AT RISK	CONTROLS	INITIAL HI...	RESIDUAL...	ACTION OWNER	BY WHEN

4 METHOD — SEQUENCE OF WORK

- 01 Confirm the system, the pump set-up position and the hose route; brief everyone working along the route.
- 02 Check the scaffold tag, loading class and ties before landing any material.
- 03 Couple hoses with safety pins and whip checks; test run and confirm signals with the pump operator.
- 04 Mask and protect openings and adjacent surfaces — overspray travels further than expected.
- 05 Spray, rule and finish in the specified thickness; nobody works in line with a pressurised hose.
- 06 Depressurise and confirm zero before breaking any coupling; clear blockages to the manufacturer's procedure.
- 07 Wash out to a contained point, never to a drain; protect fresh render from weather.

SITE-SPECIFIC AMENDMENTS TO THE SEQUENCE

5 PLANT, EQUIPMENT AND MATERIALS

- Render pump with hoses, whip checks and safety pins
- Compressor and spray gun

- Masking and protection
- Radios or agreed signals

INSPECTION / THOROUGH EXAMINATION REFS

COSHH ASSESSMENT REFS

6 PPE — THE LAST LINE OF CONTROL, NOT THE FIRST

- Head protection
- Safety footwear
- High visibility
- Gloves — task-rated
- Eye protection
- Hearing protection
- Waterproof gauntlets
- Eye and face protection against overspray
- Hearing protection near the pump

RPE TYPE, FACE-FIT STATUS, AND ANY OTHER PPE REQUIRED

7 PERMITS REQUIRED BEFORE THIS WORK STARTS

A permit authorises this work in that place, on that day. It extends the safe system of work in this document — it does not replace it (HSE HSG250). The site issues the permit; record its number before work starts.

KD-PTW-WH-006 — Work at Height Permit

For facade spraying.

PERMIT NUMBER

KD-PTW-GP-003 — General Permit to Work

For pump set-up and hose runs through occupied areas.

PERMIT NUMBER

8 EMERGENCY ARRANGEMENTS — COMPLETE FOR THIS SITE

FIRST AIDER AND LOCATION	NEAREST A&E	ASSEMBLY POINT
HOW THE ALARM IS RAISED	EMERGENCY ACCESS FOR THIS WORK AREA	SPILL / ENVIRONMENTAL RESPONSE

9 BRIEFING RECORD — EVERYONE WORKING UNDER THIS RAMS SIGNS BEFORE STARTING

By signing you confirm the contents of this RAMS have been explained to you, you understand the hazards and controls, and you will work to the sequence stated. Tell the supervisor if the work or the site does not match this document — work stops until it does.

NAME	COMPANY	SIGNATURE	DATE

10 PREPARED AND ACCEPTED

Prepared / adapted for this site by — I confirm I have adapted this document to the site, scored the risks, and that it describes how the work will actually be done.

PRINTED NAME	ROLE / COMPETENCE	COMPANY	SIGNATURE	DATE	TIME

Accepted for the site by — principal contractor or site manager review.

PRINTED NAME	ROLE	COMPANY	SIGNATURE	DATE	TIME

Review this RAMS if the work, the site or the law changes, and at least before each new phase of the works. Flatten the completed PDF before filing so the record cannot be silently edited.

R REVISION HISTORY

Every revision of this document, and every review that found nothing to change. The revision on the front of this sheet is the one you are holding — check kubitdocs.com for the current one before use.

Rev	Date	Class	What changed	Authorised by
D0	2026-08-11	first-issue	First issue.	— not yet approved —
A0	2026-08-27	review	Approved for issue by the author. Content unchanged from D0; the draft status strip is removed. No independent third-party review has been carried out.	Author — director, UK principal contractor, SMSTS. Not an independent review.

Class: first-issue · material (the law, a control, a field or the scope changed — past buyers are notified) · editorial (wording or layout only) · review (checked, nothing changed) · withdrawal. Revision prefix D = draft, not approved and not for sale; A = approved for issue by the person named, on the date shown.