

How this sheet works: the subcontractor ticks and initials each point as the work is checked. ONE named reviewer — the principal contractor's site manager or quality manager — releases every HOLD POINT on this sheet, all the way to completion. The client, contract administrator or clerk of works signs once, at the end. A stack of these signed at a desk is not evidence — every hold point needs a reading, a photo reference and a date. Issue with the activity RAMS.

1 WHERE — A STRANGER MUST BE ABLE TO FIND THIS AREA FROM THIS SHEET IN FIVE YEARS

BLOCK / BUILDING	LEVEL / FLOOR	ROOF / ABUTMENT / ELEVATION	GRIDLINES	DRAWING AND REVISION
PROJECT / SITE REF	SITE	SPEC CLAUSE / SCHEDULE	SUBCONTRACTOR INSPECTOR	REVIEWER — RELEASES THE HOLD POINTS

2 THE SPECIFIED SYSTEM — FROM THE SPECIFICATION AND THE DRAWINGS, NOT FROM MEMORY

FLASHING DETAILS AND REVISION	LEAD CODE BY DETAIL (DRAWING)	MAXIMUM PIECE LENGTH AND LAP (SPECIFICATION)
CHASE DEPTH AND FIXING (SPECIFICATION)	UPSTAND HEIGHT ABOVE THE ROOF SURFACE (DRAWING)	PATINATION OIL / UNDERLAY SPECIFIED

3. Materials on site

HOLD POINT

Every product is the one the specification and the system data sheet name — one system, no mixing of makers' membranes, primers, insulation and accessories; the material approval on KD-QA-SYS-005 referenced

Spec · TDS

Batch numbers recorded; within shelf life; stored as the data sheet states — rolls on end or flat as directed, insulation dry and covered

TDS

BATCH NUMBERS	KD-QA-SYS-005 REF					
RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo
SUB SELF-CHECK — INITIALS	DATE	HOLD RELEASED BY THE REVIEWER — SIGNATURE			TIME	DATE

4. Lead code and material

HOLD POINT

Lead sheet is the code in section 2 for each detail — the code marking on the roll checked and recorded; no thinner code substituted

BS EN 12588

Non-lead flashings (where specified) are the product the specification names and the profile on the drawing

Spec · TDS

CODES SEEN ON ROLLS / DETAILS USED						
RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo
SUB SELF-CHECK — INITIALS	DATE	HOLD RELEASED BY THE REVIEWER — SIGNATURE			TIME	DATE

5. Lengths, laps and upstands

HOLD POINT

No piece longer than the figure in section 2; laps at least the figure in section 2 and in the direction of the fall; upstands at least the height in section 2 above the finished roof — measured and the smallest recorded

Practice · Spec

Step flashings cut to the course lines with each step lapping the next by the figure the specification states; soakers under every course at slate abutments of the size drawn

Practice · Drawing

Cover flashings lap over the upstand of the waterproofing by at least 75 mm and are free to move — not bonded to the membrane where the detail shows a separate cover flashing

BS 6229 · Drawing

LONGEST PIECE / SMALLEST LAP / SMALLEST UPSTAND MEASURED

RESULT ☐ Pass ☐ Fail ☐ N/A NCR REF IF FAIL PHOTO REF(S) Date/time on photo

SUB SELF-CHECK — INITIALS DATE HOLD RELEASED BY THE REVIEWER — SIGNATURE TIME DATE

6. Chases, fixings and dressing

HOLD POINT

Chases cut to the depth in section 2, the lead turned in fully and wedged with the fixings and at the spacing in section 2, then pointed with the sealant or mortar the specification names

Spec

Lead dressed to the tile or slate profile without thinning or cracking; clips at the free edges at the spacing the specification states so nothing lifts in wind; no fixings through the lead in a position that stops movement

Practice

Underlay or separating layer under lead on timber or over new mortar as the data sheet requires

TDS

RESULT ☐ Pass ☐ Fail ☐ N/A NCR REF IF FAIL PHOTO REF(S) Date/time on photo

SUB SELF-CHECK — INITIALS DATE HOLD RELEASED BY THE REVIEWER — SIGNATURE TIME DATE

7. Finish and protection

CHECK & RECORD

Patination oil applied to the whole surface on the day of fixing where specified; no lead in contact with materials the data sheet forbids; runs below lead protected from staining as the drawing details

TDS

RESULT ☐ Pass ☐ Fail ☐ N/A NCR REF IF FAIL PHOTO REF(S) Date/time on photo

SUB SELF-CHECK — INITIALS DATE

8. Snagging closed and handover

HOLD POINT

Every snag and non-conformance below closed and re-checked by someone other than the person who fixed it

Practice

Roof clean of debris, offcuts and fixings; outlets and gutters clear and running; protection to the finished covering where following trades will cross it

BS 6229

System guarantee application, installation record and photographs handed over and referenced

TDS

RESULT ☐ Pass ☐ Fail ☐ N/A NCR REF IF FAIL PHOTO REF(S) Date/time on photo

SUB SELF-CHECK — INITIALS DATE HOLD RELEASED BY THE REVIEWER — SIGNATURE TIME DATE

9 SNAGS FOUND IN THIS AREA — MINOR DEFECTS FIXED AND RE-CHECKED ON THE SHEET

A snag is a defect the trade puts right and someone else re-checks. Anything that fails an acceptance criterion outright, or cannot be fixed in the area, is a non-conformance and goes in the next section instead.

NO.	WHERE (ELEMENT / POSITION)	DEFECT FOUND	FIXED BY / DATE	RE-CHECKED BY / DATE...	OK?

10 NON-CONFORMANCES FOR THIS AREA — ONE BLOCK PER NCR; CLOSED BY SOMEONE OTHER THAN THE FIXER

NCR 1 — REFERENCE POINT OWNER (NAMED PERSON) DUE STATUS

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE

RE-INSPECTED BY (NOT THE FIXER) / DATE

PHOTO REF(S)

NCR 2 — REFERENCE POINT OWNER (NAMED PERSON) DUE STATUS

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE

RE-INSPECTED BY (NOT THE FIXER) / DATE

PHOTO REF(S)

NCR 3 — REFERENCE POINT OWNER (NAMED PERSON) DUE STATUS

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE

RE-INSPECTED BY (NOT THE FIXER) / DATE

PHOTO REF(S)

11 PHOTO LOG — WHAT EACH PHOTO REFERENCE SHOWS

PHOTO REF	POINT	WHAT IT SHOWS (LOCATION, ELEMENT, READING VISIBLE)	DATE / TIME	TAKEN BY

12 NOTES FOR THIS AREA

ANYTHING THE NEXT PERSON NEEDS TO KNOW — AGREEMENTS, DEVIATIONS FROM THE SPECIFICATION, ACCESS LIMITS, ITEMS CARRIED TO THE NEXT VISIT

13 RELEASE

The reviewer confirms every hold point on this sheet was released and every snag and non-conformance is closed; the client, contract administrator or clerk of works then signs once. This sheet goes in the handover file with the photos it references.

Subcontractor — work complete and self-checked:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

Reviewer — all hold points released, all snags and non-conformances closed:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

Client / contract administrator / clerk of works — final sign-off:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

R REVISION HISTORY

Every revision of this document, and every review that found nothing to change. The revision on the front of this sheet is the one you are holding — check kubitdocs.com for the current one before use.

Rev	Date	Class	What changed	Authorised by
D0	2026-08-29	first-issue	First issue.	— not yet approved —
A0	2026-08-29	review	Approved for issue by the author. Content unchanged from the draft; the draft status strip is removed. No independent third-party review has been carried out.	Author — director, UK principal contractor, SMSTS. Not an independent review.

Class: first-issue · material (the law, a control, a field or the scope changed — past buyers are notified) · editorial (wording or layout only) · review (checked, nothing changed) · withdrawal. Revision prefix D = draft, not approved and not for sale; A = approved for issue by the person named, on the date shown.