

INSPECTION AND TEST PLAN — SCREED

DPM, insulation and UFH test before the pour, datums released, the RH reading before any finish goes down

PLAN — ONE PER PACKAGE

KD-ITP-SC-032 Rev A0

An inspection and test plan is the list of what will be inspected or tested at each stage of this package, against what acceptance criterion and how often, who holds the work, witnesses it, keeps it under surveillance or reviews the record, and which record proves it. On a screed package the pour is released as a hold — DPM, insulation, edge strip and the underfloor heating test all seen first — and the relative humidity reading before any finish goes down is the numeric hold nobody may guess. The stages below are the ones the area checklists cover, so the R column points to a sheet that exists — the KD-QA sheets are the records; the package cover sheet KD-QA-SYS-001 is the cover the client signs with the register of sheets raised under it; this is the plan behind both. Where this plan exists, section 3 of KD-QA-SYS-001 (and of KD-QA-PD-100 for decoration) is completed as "see this plan" and the letters are agreed here, so nothing is agreed twice. Nothing on this sheet is an acceptance value: the specification reference and the criterion are written in from the specification, and H, W, S and R are agreed with the client before the first stage starts. A failed hold raises KD-QA-SYS-007 and the line stays open until it is re-inspected.

1 PACKAGE

PROJECT / SITE REF		SITE		DATE		PACKAGE / SUBCONTRACTOR		PLAN PREPARED BY			
SPECIFICATION, DRAWINGS AND REVISIONS THIS PACKAGE IS BUILT TO				PRINCIPAL CONTRACTOR'S REVIEWER		CLIENT'S REPRESENTATIVE		NOTICE FOR H AND W POINTS		PLAN REV	

2 THE PLAN — ONE LINE PER STAGE, IN THE ORDER THE WORK IS BUILT

H hold — work stops until released · W witness — notice given, work proceeds if they do not attend · S surveillance — checked without stopping the work · R review of the record only. One letter per party per line; a blank means that party takes no part in the stage.

NO	STAGE / ACTIVITY	SPEC REF	INSPECTION OR TEST	ACCEPTANCE	FREQUENCY	SUB	PC	CLIENT	RECORD REF	SIGN-OFF
1	Substrate		Clean, sound, level		Each area				KD-QA-SC-001	
2	DPM, insulation and edge strip		Before the pour		Each area				KD-QA-SC-001	
3	Underfloor heating pipes and test		Pressure test before the screed		Each zone				KD-QA-SC-001/ME-007	
4	Datums, thickness and reinforcement		Released for the pour		Each area				KD-QA-SC-001	
5	Materials and mix		Delivery tickets; mix as specified		Each load				KD-QA-SC-001	
6	The pour, finish and curing		Placing, finish, cure		Each pour				KD-QA-SC-001	
7	Drying conditions and period		Conditions logged		Daily				KD-QA-SC-002	
8	Relative humidity test		Reading against the specified figure		Each area				KD-QA-SC-002	
9	Underfloor heating first heating		Heating cycle before finishes		Each zone				KD-QA-SC-002	
10	Flatness and surface		Straightedge against the tolerance		Each area				KD-QA-SC-002/003	
11	Levelling compound - preparation		Primer; application		Each area				KD-QA-SC-003	
12	Release for the finish		Reviewer release		Each area				KD-QA-SC-003	

INSPECTION AND TEST PLAN — SCREED

continued

PLAN — ONE PER PACKAGE

KD-ITP-SC-032 Rev A0

3 SIGN-OFF CHAIN

The subcontractor prepares the plan from the specification and the sequence it will build to. The principal contractor's reviewer accepts it: the stages are complete, every record named exists, and every hold falls before the work it protects is covered. The client's representative agrees the H, W, S and R columns and the notice period. A line is closed in the last column by the party holding the highest intervention on it; the area checklists carry the signatures for the checks themselves. Revise and re-sign when the specification, the sequence or the subcontractor changes.

Prepared by — subcontractor:

PRINTED NAME	ROLE	COMPANY	SIGNATURE	DATE	TIME

Accepted by — principal contractor's reviewer:

PRINTED NAME	ROLE	COMPANY	SIGNATURE	DATE	TIME

Agreed by — client's representative:

PRINTED NAME	ROLE	COMPANY	SIGNATURE	DATE	TIME

R REVISION HISTORY

Every revision of this document, and every review that found nothing to change. The revision on the front of this sheet is the one you are holding — check kubitdocs.com for the current one before use.

Rev	Date	Class	What changed	Authorised by
D0	2026-09-02	first-issue	First issue.	— not yet approved —
A0	2026-09-02	review	Approved for issue by the author. Content unchanged from the reviewed draft; the draft status strip is removed. No independent third-party review has been carried out.	Author — director, UK principal contractor, SMSTS. Not an independent review.

Class: first-issue · material (the law, a control, a field or the scope changed — past buyers are notified) · editorial (wording or layout only) · review (checked, nothing changed) · withdrawal. Revision prefix D = draft, not approved and not for sale; A = approved for issue by the person named, on the date shown.