

How this sheet works: the subcontractor ticks and initials each point as the work is checked. ONE named reviewer — the principal contractor's site manager or quality manager — releases every HOLD POINT on this sheet, all the way to completion. The client, contract administrator or clerk of works signs once, at the end. A stack of these signed at a desk is not evidence — every hold point needs a reading, a photo reference and a date. Issue with the activity RAMS.

1 WHERE — A STRANGER MUST BE ABLE TO FIND THIS AREA FROM THIS SHEET IN FIVE YEARS

BLOCK / BUILDING	LEVEL / FLOOR	ELEMENT / AREA (WALL, SLAB, LIFT PIT)	GRIDLINES	DRAWING AND REVISION
PROJECT / SITE REF	SITE	SPEC CLAUSE / SCHEDULE	SUBCONTRACTOR INSPECTOR	REVIEWER — RELEASES THE HOLD POINTS

2 THE SPECIFIED SYSTEM — FROM THE SPECIFICATION AND THE DRAWINGS, NOT FROM MEMORY

INTEGRITY TEST METHOD FROM THE SPECIFICATION	TESTER (ORGANISATION REF) / DATE	PROTECTION BOARD / LAYER SPECIFIED
DRAINAGE LAYER / LAND DRAIN SPECIFIED	BACKFILL MATERIAL SPECIFIED AGAINST THE WALL	PROTECTION TO BE KEPT CLEAR OF (LIST)

3. Integrity test

HOLD POINT

Test by the method in section 2 over the whole area including details and penetrations; the result recorded and the report referenced	Spec
Every defect found marked on the membrane and on a sketch, repaired by the data-sheet method and re-tested; both results recorded	TDS
Flood tests held for the duration the specification states with the water level recorded at the start and end	Spec
TEST REPORT REF / DEFECTS FOUND / RE-TEST RESULT	

RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo
SUB SELF-CHECK — INITIALS	DATE	HOLD RELEASED BY THE REVIEWER — SIGNATURE		TIME	DATE	

4. Protection board and layers

HOLD POINT

Protection of the product in section 2 over the whole membrane, fixed as the data sheet states — no fixings through the membrane; boards butted, not lapped over drainage outlets	TDS
Drainage layer, filter fabric and land drain at the positions and levels the drawing shows; the drain connected to the outfall and tested	Drawing
Protection inspected the morning of backfill; any displaced or damaged board replaced first	TDS
PHOTO REFS — PROTECTION AND DRAINAGE IN PLACE	

RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo
SUB SELF-CHECK — INITIALS	DATE	HOLD RELEASED BY THE REVIEWER — SIGNATURE		TIME	DATE	

5. Backfill

HOLD POINT

Backfill of the material in section 2, placed in layers as KD-QA-GW-003 with no plant compaction within the distance of the wall the drawing states; no boulders, rubble or sharp material against the protection

Spec

Backfill only after the wall has reached the age or strength the specification states and is propped where the design requires

BS 8102 - Spec

BACKFILL STARTED / COMPLETED (DATES)

RESULT ☐ Pass ☐ Fail ☐ N/A NCR REF IF FAIL PHOTO REF(S) Date/time on photo

SUB SELF-CHECK — INITIALS DATE HOLD RELEASED BY THE REVIEWER — SIGNATURE TIME DATE

6. Records

CHECK & RECORD

Test report, photographs, repair record and the system's installation record handed over and referenced; the waterproofing designer's sign-off recorded where the specification requires

BS 8102

RESULT ☐ Pass ☐ Fail ☐ N/A NCR REF IF FAIL PHOTO REF(S) Date/time on photo

SUB SELF-CHECK — INITIALS DATE

7 SNAGS FOUND IN THIS AREA — MINOR DEFECTS FIXED AND RE-CHECKED ON THE SHEET

A snag is a defect the trade puts right and someone else re-checks. Anything that fails an acceptance criterion outright, or cannot be fixed in the area, is a non-conformance and goes in the next section instead.

NO.	WHERE (ELEMENT / POSITION)	DEFECT FOUND	FIXED BY / DATE	RE-CHECKED BY / DAT...	OK?

8 NON-CONFORMANCES FOR THIS AREA — ONE BLOCK PER NCR; CLOSED BY SOMEONE OTHER THAN THE FIXER

NCR 1 — REFERENCE POINT OWNER (NAMED PERSON) DUE STATUS

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE RE-INSPECTED BY (NOT THE FIXER) / DATE PHOTO REF(S)

NCR 2 — REFERENCE	POINT	OWNER (NAMED PERSON)	DUE	STATUS
WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT				
CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN				
FIXED BY / DATE		RE-INSPECTED BY (NOT THE FIXER) / DATE		PHOTO REF(S)

NCR 3 — REFERENCE	POINT	OWNER (NAMED PERSON)	DUE	STATUS
WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT				
CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN				
FIXED BY / DATE		RE-INSPECTED BY (NOT THE FIXER) / DATE		PHOTO REF(S)

9 PHOTO LOG — WHAT EACH PHOTO REFERENCE SHOWS

PHOTO REF	POINT	WHAT IT SHOWS (LOCATION, ELEMENT, READING VISIBLE)	DATE / TIME	TAKEN BY

10 NOTES FOR THIS AREA

ANYTHING THE NEXT PERSON NEEDS TO KNOW — AGREEMENTS, DEVIATIONS FROM THE SPECIFICATION, ACCESS LIMITS, ITEMS CARRIED TO THE NEXT VISIT

11 RELEASE

The reviewer confirms every hold point on this sheet was released and every snag and non-conformance is closed; the client, contract administrator or clerk of works then signs once. This sheet goes in the handover file with the photos it references.

Subcontractor — work complete and self-checked:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

Reviewer — all hold points released, all snags and non-conformances closed:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

Client / contract administrator / clerk of works — final sign-off:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

R REVISION HISTORY

Every revision of this document, and every review that found nothing to change. The revision on the front of this sheet is the one you are holding — check kubitdocs.com for the current one before use.

Rev	Date	Class	What changed	Authorised by
D0	2026-08-29	first-issue	First issue.	— not yet approved —
A0	2026-08-29	review	Approved for issue by the author. Content unchanged from the draft; the draft status strip is removed. No independent third-party review has been carried out.	Author — director, UK principal contractor, SMSTS. Not an independent review.

Class: first-issue · material (the law, a control, a field or the scope changed — past buyers are notified) · editorial (wording or layout only) · review (checked, nothing changed) · withdrawal. Revision prefix D = draft, not approved and not for sale; A = approved for issue by the person named, on the date shown.