

PRESSURE TESTING AND FLUSHING

ACTIVITY RAMS — ADAPT TO SITE BEFORE USE

Hydraulic and air testing · system flushing · chemical cleaning interface

KD-RAMS-ME-006 Rev A0

Statutory basis: HSWA 1974 s.2(2)(a) and MHSWR 1999 regs 3 and 5 (this document is the recorded safe system of work); PUWER 1998; Manual Handling Operations Regulations 1992; Work at Height Regulations 2005; COSHH 2002; CDM 2015 regs 13 and 15. Activity-specific law is cited on the documents it applies to: Gas Safety (Installation and Use) Regulations 1998, the Fluorinated Greenhouse Gases Regulations 2015 for refrigerant handling, and ACOP L8 (4th edition, 2013) for water systems.

1 DOCUMENT AND PROJECT IDENTIFICATION

RAMS REFERENCE	PROJECT / SITE REF	SITE NAME AND ADDRESS	DATE PREPARED	NEXT REVIEW DATE
CLIENT / PRINCIPAL CONTRACTOR	PLANNED START	DURATION	OPERATIVES	SUPERVISING THE WORK

2 SCOPE OF WORKS

Pressure testing of completed pipework (hydraulic preferred, air only where justified) and system flushing to the water treatment specification, including test records and certificates.

This document does not cover: gas tightness testing (KD-RAMS-ME-007, Gas Safe engineers), and chemical cleaning by the specialist under their own documents.

SITE-SPECIFIC SCOPE, LOCATIONS AND LIMITATIONS

3 RISK ASSESSMENT — SCORE EACH RISK FOR THIS SITE, THEN ADD WHAT IS MISSING

The hazards and controls below are the starting point for this activity, written by a working main contractor. They are not complete for your site until a competent person has scored each risk, added the site-specific hazards, and struck out anything that does not apply. Rate risks High / Medium / Low before and after controls.

1. Legionella and water hygiene during filling, flushing and commissioning

At risk: Operatives, building occupants

Controls: Work to the water hygiene plan and ACOP L8 guidance: no stagnant sections left charged, flushing regimes recorded, disinfection to the specification with certificates retained, dead-legs removed not abandoned.

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

2. Slips, trips and housekeeping

At risk: Everyone in the work area

Controls: Keep the workface clear, remove waste and offcuts as they are created, route leads at high level or under mats, and maintain task lighting.

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

3. Manual handling of pipe, ductwork, plant and sanitaryware

At risk: Operatives

Controls: Mechanical aids first — pipe trolleys, duct lifters, stair-climbers, genies for plant; two-person lifts as the default for lengths and units; order in manageable sections; protect the route.

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

4. Stored energy in test pressure — component failure under test

At risk: Everyone near the system

Controls: Hydraulic testing as the default — air testing only with written justification at the lowest practicable pressure; exclusion of non-involved persons during pressurisation; rated test equipment with calibrated gauges; never work on a pressurised joint; depressurise before any adjustment.

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

5. Water escape damaging the building or live areas

At risk: The building, occupants

Controls: Walk the system before filling: open ends capped, drains identified; filling attended, never left; spill kit and wet-vac at hand; agree flooding response with the site before the first fill.

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

Site-specific hazards not listed above — every site has at least one:

HAZARD	WHO IS AT RISK	CONTROLS	INITIAL HI...	RESIDUAL...	ACTION OWNER	BY WHEN

PRESSURE TESTING AND FLUSHING

continued

ACTIVITY RAMS — ADAPT TO SITE BEFORE USE

KD-RAMS-ME-006 Rev A0

4 METHOD — SEQUENCE OF WORK

- 01 Confirm the system section is complete and every open end capped; isolate from sections not under test.
- 02 Fill slowly from the low point, venting air; attend the fill throughout.
- 03 Pressurise in stages to the specified test pressure; hold and record per the specification.
- 04 Inspect joints without touching pressurised components; depressurise before any remedial work.
- 05 Flush to the water treatment specification; record velocities/durations; certificates retained.
- 06 Drain-down or leave charged per the water hygiene plan — no stagnant sections.

SITE-SPECIFIC AMENDMENTS TO THE SEQUENCE

5 PLANT, EQUIPMENT AND MATERIALS

Test pumps with calibrated gauges

Hoses rated for test pressure

Wet-vac and spill kit

INSPECTION / THOROUGH EXAMINATION REFS

COSHH ASSESSMENT REFS

6 PPE — THE LAST LINE OF CONTROL, NOT THE FIRST

Head protection

Safety footwear

High visibility

Gloves — task-rated

Eye protection

Hearing protection

RPE TYPE, FACE-FIT STATUS, AND ANY OTHER PPE REQUIRED

7 PERMITS REQUIRED BEFORE THIS WORK STARTS

A permit authorises this work in that place, on that day. It extends the safe system of work in this document — it does not replace it (HSE HSG250). The site issues the permit; record its number before work starts.

KD-PTW-GP-003 — General Permit to Work

Where the site requires a permit for pressure testing.

PERMIT NUMBER

8 EMERGENCY ARRANGEMENTS — COMPLETE FOR THIS SITE

FIRST AIDER AND LOCATION

NEAREST A&E

ASSEMBLY POINT

HOW THE ALARM IS RAISED

EMERGENCY ACCESS FOR THIS WORK AREA

SPILL / ENVIRONMENTAL RESPONSE

9 BRIEFING RECORD — EVERYONE WORKING UNDER THIS RAMS SIGNS BEFORE STARTING

By signing you confirm the contents of this RAMS have been explained to you, you understand the hazards and controls, and you will work to the sequence stated. Tell the supervisor if the work or the site does not match this document — work stops until it does.

NAME	COMPANY	SIGNATURE	DATE

PRESSURE TESTING AND FLUSHING

continued

ACTIVITY RAMS — ADAPT TO SITE BEFORE USE

KD-RAMS-ME-006 Rev A0

10 PREPARED AND ACCEPTED

Prepared / adapted for this site by — I confirm I have adapted this document to the site, scored the risks, and that it describes how the work will actually be done.

PRINTED NAME	ROLE / COMPETENCE	COMPANY	SIGNATURE	DATE	TIME

Accepted for the site by — principal contractor or site manager review.

PRINTED NAME	ROLE	COMPANY	SIGNATURE	DATE	TIME

Review this RAMS if the work, the site or the law changes, and at least before each new phase of the works. Flatten the completed PDF before filing so the record cannot be silently edited.

R REVISION HISTORY

Every revision of this document, and every review that found nothing to change. The revision on the front of this sheet is the one you are holding — check kubitdocs.com for the current one before use.

Rev	Date	Class	What changed	Authorised by
D0	2026-08-09	first-issue	First issue.	— not yet approved —
D1	2026-08-10	material	Refrigerant law cited properly as the Fluorinated Greenhouse Gases Regulations 2015 in place of "the F-Gas Regulation"; ACOP L8 dated to the 4th edition, 2013; COSHH 2002 added to the legal basis. Legislation position reviewed against Product Legislation Register KD-REG-01 Rev R01.3 and the August 2026 horizon scan; cutoff moved to 10 August 2026.	— not yet approved —
A0	2026-08-27	review	Approved for issue by the author. Content unchanged from D1; the draft status strip is removed. No independent third-party review has been carried out.	Author — director, UK principal contractor, SMSTS. Not an independent review.

Class: first-issue · material (the law, a control, a field or the scope changed — past buyers are notified) · editorial (wording or layout only) · review (checked, nothing changed) · withdrawal. Revision prefix D = draft, not approved and not for sale; A = approved for issue by the person named, on the date shown.