

SEALING, INTERFACES AND WATER TESTING — QUALITY INSPECTION CHECKLIST

QUALITY — ONE PER AREA

Every interface sealed to the detail, then tested to the specification with the results on the sheet · one sheet per elevation or zone

KD-QA-CL-005 Rev A0

How this sheet works: the subcontractor ticks and initials each point as the work is checked. ONE named reviewer — the principal contractor's site manager or quality manager — releases every HOLD POINT on this sheet, all the way to completion. The client, contract administrator or clerk of works signs once, at the end. A stack of these signed at a desk is not evidence — every hold point needs a reading, a photo reference and a date. Issue with the activity RAMS.

1 WHERE — A STRANGER MUST BE ABLE TO FIND THIS AREA FROM THIS SHEET IN FIVE YEARS

BLOCK / BUILDING	LEVEL / FLOOR	ELEVATION / ZONE / GRIDLINES	GRIDLINES	DRAWING AND REVISION
PROJECT / SITE REF	SITE	SPEC CLAUSE / SCHEDULE	SUBCONTRACTOR INSPECTOR	REVIEWER — RELEASES THE HOLD POINTS

2 THE SPECIFIED SYSTEM — FROM THE SPECIFICATION AND THE DRAWINGS, NOT FROM MEMORY

INTERFACE DETAILS AND REVISION	INTERFACES ON THIS SHEET (LIST)	SEALANTS SPECIFIED BY INTERFACE (PRO...
WATER TEST METHOD / EXTENT / PASS CRITERION	TESTER (NAME OR ORGANISATION REF)	INTERFACE MEMBRANES / TAPES SPECIFIED

3. Interface membranes and tapes

HOLD POINT

Every interface in section 2 has the membrane or tape the detail shows, bonded to both substrates over the width the data sheet states, lapped in the direction of drainage, and photographed before closures cover it

Drawing · TDS

RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo
SUB SELF-CHECK — INITIALS	DATE	HOLD RELEASED BY THE REVIEWER — SIGNATURE		TIME	DATE	

4. Sealant joints

HOLD POINT

Joint widths within the range the sealant data sheet allows; backing rod of the size stated; primer where the data sheet requires it; substrates clean and dry; sealant tooled to the profile drawn

TDS

Applied within the data-sheet temperature range; adhesion tested on the first joints of each substrate combination after cure and the result recorded

TDS

ADHESION TEST RESULTS (SUBSTRATE / RESULT)						
RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo
SUB SELF-CHECK — INITIALS	DATE	HOLD RELEASED BY THE REVIEWER — SIGNATURE		TIME	DATE	

5. Water test

HOLD POINT

Test by the method and to the extent in section 2 with an observer inside the building; areas tested and the result recorded; any ingress traced to its cause, repaired and re-tested with both results on this sheet

CWCT · Spec

TEST REPORT REF / AREAS / RESULT / RE-TEST						
RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo
SUB SELF-CHECK — INITIALS	DATE	HOLD RELEASED BY THE REVIEWER — SIGNATURE		TIME	DATE	

6. Records

CHECK & RECORD

Test reports, adhesion results and photographs referenced and filed with the elevation's handover record

Practice

RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo
--------	------	------	-----	-----------------	--------------	--------------------

SUB SELF-CHECK — INITIALS DATE

7 SNAGS FOUND IN THIS AREA — MINOR DEFECTS FIXED AND RE-CHECKED ON THE SHEET

A snag is a defect the trade puts right and someone else re-checks. Anything that fails an acceptance criterion outright, or cannot be fixed in the area, is a non-conformance and goes in the next section instead.

[illegible]

8 NON-CONFORMANCES FOR THIS AREA — ONE BLOCK PER NCR; CLOSED BY SOMEONE OTHER THAN THE FIXER

NCR 1 — REFERENCE	POINT	OWNER (NAMED PERSON)	DUE	STATUS
-------------------	-------	----------------------	-----	--------

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE	RE-INSPECTED BY (NOT THE FIXER) / DATE	PHOTO REF(S)

NCR 2 — REFERENCE	POINT	OWNER (NAMED PERSON)	DUE	STATUS

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION: WHERE: EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE	RE-INSPECTED BY (NOT THE FIXER) / DATE	PHOTO REF(S)

NCR 3 — REFERENCE	POINT	OWNER (NAMED PERSON)	DUE	STATUS

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION: WHERE: EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE	RE-INSPECTED BY (NOT THE FIXER) / DATE	PHOTO REF(S)

9 PHOTO LOG — WHAT EACH PHOTO REFERENCE SHOWS

PHOTO REF	POINT	WHAT IT SHOWS (LOCATION, ELEMENT, READING VISIBLE)	DATE / TIME	TAKEN BY

10 NOTES FOR THIS AREA

ANYTHING THE NEXT PERSON NEEDS TO KNOW — AGREEMENTS, DEVIATIONS FROM THE SPECIFICATION, ACCESS LIMITS, ITEMS CARRIED TO THE NEXT VISIT

11 RELEASE

The reviewer confirms every hold point on this sheet was released and every snag and non-conformance is closed; the client, contract administrator or clerk of works then signs once. This sheet goes in the handover file with the photos it references.

Subcontractor — work complete and self-checked:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

Reviewer — all hold points released, all snags and non-conformances closed:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

Client / contract administrator / clerk of works — final sign-off:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

R REVISION HISTORY

Every revision of this document, and every review that found nothing to change. The revision on the front of this sheet is the one you are holding — check kubitdocs.com for the current one before use.

Rev	Date	Class	What changed	Authorised by
D0	2026-08-29	first-issue	First issue.	— not yet approved —
A0	2026-08-29	review	Approved for issue by the author. Content unchanged from the draft; the draft status strip is removed. No independent third-party review has been carried out.	Author — director, UK principal contractor, SMSTS. Not an independent review.

Class: first-issue · material (the law, a control, a field or the scope changed — past buyers are notified) · editorial (wording or layout only) · review (checked, nothing changed) · withdrawal. Revision prefix D = draft, not approved and not for sale; A = approved for issue by the person named, on the date shown.