

SECONDARY STEEL — LINTELS, STAIRS AND MEZZANINES — QUALITY INSPECTI... QUALITY — ONE PER AREA

Fixings proved, levels and rise-and-going measured, handrails and edge protection complete before handover · one sheet per ele... KD-QA-ST-006 Rev A0

How this sheet works: the subcontractor ticks and initials each point as the work is checked. ONE named reviewer — the principal contractor's site manager or quality manager — releases every HOLD POINT on this sheet, all the way to completion. The client, contract administrator or clerk of works signs once, at the end. A stack of these signed at a desk is not evidence — every hold point needs a reading, a photo reference and a date. Issue with the activity RAMS.

1 WHERE — A STRANGER MUST BE ABLE TO FIND THIS AREA FROM THIS SHEET IN FIVE YEARS

BLOCK / BUILDING	LEVEL / FLOOR	ELEMENT GROUP / LOCATION	GRIDLINES	DRAWING AND REVISION
PROJECT / SITE REF	SITE	SPEC CLAUSE / SCHEDULE	SUBCONTRACTOR INSPECTOR	REVIEWER — RELEASES THE HOLD POINTS

2 THE SPECIFIED SYSTEM — FROM THE SPECIFICATION AND THE DRAWINGS, NOT FROM MEMORY

SECONDARY STEEL DRAWINGS REVISION	ELEMENTS ON THIS SHEET	FIXINGS / ANCHORS SPECIFIED (TYPE / SIZE / EMBEDMENT)
ANCHOR SITE TEST REGIME FROM THE SPECIFICATION	LEVEL AND RISE / GOING TOLERANCES FROM THE SPECIFICATION	COATING / GALVANISING SPECIFICATION

3. Materials and certificates

CHECK & RECORD

Members and fabricated items match the drawings and carry their piece marks; the fabricator's conformity and coating certificates referenced; damage recorded for repair BS EN 1090 · Spec

RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo
SUB SELF-CHECK — INITIALS		DATE				

4. Fixings and anchors

HOLD POINT

- BS 8539 · TDS
- BS 8539
- Drawing

ANCHOR TESTS — COUNT / LOADS / RESULTS	LINTEL BEARINGS MEASURED (MM)
--	-------------------------------

RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo	
SUB SELF-CHECK — INITIALS		DATE		HOLD RELEASED BY THE REVIEWER — SIGNATURE		TIME	DATE

5. Levels, plumb and stairs

HOLD POINT

- Drawing
- Drawing

RISE / GOING MEASURED (MIN / MAX) PER FLIGHT

RESULT	Pass	Fail	N/A	NCR REF IF FAIL	PHOTO REF(S)	Date/time on photo	
SUB SELF-CHECK — INITIALS		DATE		HOLD RELEASED BY THE REVIEWER — SIGNATURE		TIME	DATE

6. Handrails, balustrades and edge protection

HOLD POINT

- Handrail and balustrade heights measured against the drawing; infill gaps no larger than the drawing states; fixings as drawn and tight
- Drawing
- Mezzanine edge protection, gates and kick plates complete as drawn before the deck is used
- Drawing

HANDRAIL / BALUSTRADE HEIGHTS MEASURED (MM)

RESULT

Pass

Fail

N/A

NCR REF IF FAIL

PHOTO REF(S)

Date/time on photo

SUB SELF-CHECK — INITIALS

DATE

HOLD RELEASED BY THE REVIEWER — SIGNATURE

TIME

DATE

7. Coating and handover

CHECK & RECORD

- Coating undamaged or repaired to the specification; galvanised work repaired with the product the specification names; readings recorded
- Spec · TDS
- Load rating plates fitted to mezzanines where the specification requires; the structure file references handed over
- Spec

RESULT

Pass

Fail

N/A

NCR REF IF FAIL

PHOTO REF(S)

Date/time on photo

SUB SELF-CHECK — INITIALS

DATE

8 SNAGS FOUND IN THIS AREA — MINOR DEFECTS FIXED AND RE-CHECKED ON THE SHEET

A snag is a defect the trade puts right and someone else re-checks. Anything that fails an acceptance criterion outright, or cannot be fixed in the area, is a non-conformance and goes in the next section instead.

NO.	WHERE (ELEMENT / POSITION)	DEFECT FOUND	FIXED BY / DATE	RE-CHECKED BY / DAT...	OK?

9 NON-CONFORMANCES FOR THIS AREA — ONE BLOCK PER NCR; CLOSED BY SOMEONE OTHER THAN THE FIXER

NCR 1 — REFERENCE	POINT	OWNER (NAMED PERSON)	DUE	STATUS

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE

RE-INSPECTED BY (NOT THE FIXER) / DATE

PHOTO REF(S)

NCR 2 — REFERENCE	POINT	OWNER (NAMED PERSON)	DUE	STATUS

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE	RE-INSPECTED BY (NOT THE FIXER) / DATE	PHOTO REF(S)

NCR 3 — REFERENCE	POINT	OWNER (NAMED PERSON)	DUE	STATUS

WHAT WAS FOUND — AGAINST WHICH ACCEPTANCE CRITERION; WHERE; EXTENT

CORRECTIVE ACTION, AND WHAT STOPS IT HAPPENING AGAIN

FIXED BY / DATE	RE-INSPECTED BY (NOT THE FIXER) / DATE	PHOTO REF(S)

10 PHOTO LOG — WHAT EACH PHOTO REFERENCE SHOWS

PHOTO REF	POINT	WHAT IT SHOWS (LOCATION, ELEMENT, READING VISIBLE)	DATE / TIME	TAKEN BY

11 NOTES FOR THIS AREA

ANYTHING THE NEXT PERSON NEEDS TO KNOW — AGREEMENTS, DEVIATIONS FROM THE SPECIFICATION, ACCESS LIMITS, ITEMS CARRIED TO THE NEXT VISIT

12 RELEASE

The reviewer confirms every hold point on this sheet was released and every snag and non-conformance is closed; the client, contract administrator or clerk of works then signs once. This sheet goes in the handover file with the photos it references.

Subcontractor — work complete and self-checked:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

Reviewer — all hold points released, all snags and non-conformances closed:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

Client / contract administrator / clerk of works — final sign-off:

PRINTED NAME	ROLE / POSITION	COMPANY	SIGNATURE	DATE	TIME

R REVISION HISTORY

Every revision of this document, and every review that found nothing to change. The revision on the front of this sheet is the one you are holding — check kubitdocs.com for the current one before use.

Rev	Date	Class	What changed	Authorised by
D0	2026-08-29	first-issue	First issue.	— not yet approved —
A0	2026-08-29	review	Approved for issue by the author. Content unchanged from the draft; the draft status strip is removed. No independent third-party review has been carried out.	Author — director, UK principal contractor, SMSTS. Not an independent review.

Class: first-issue · material (the law, a control, a field or the scope changed — past buyers are notified) · editorial (wording or layout only) · review (checked, nothing changed) · withdrawal. Revision prefix D = draft, not approved and not for sale; A = approved for issue by the person named, on the date shown.