

SECONDARY STEELWORK AND INFILL MEMBERS

ACTIVITY RAMS — ADAPT TO SITE BEFORE USE

Purlins · rails · infill beams · connections to the primary frame

KD-RAMS-ST-002 Rev A0

Statutory basis: HSWA 1974 s.2(2)(a) and MHSWR 1999 regs 3 and 5; Work at Height Regulations 2005; LOLER 1998 reg 8 with BS 7121-1:2016 for the lifting; erection stability per the engineer's scheme and BS 5975-1:2024 principles; PUWER 1998; COSHH 2002 for welding fume, coatings and solvents; CDM 2015 regs 13 and 15. Hot works under the permit system.

1 DOCUMENT AND PROJECT IDENTIFICATION

RAMS REFERENCE	PROJECT / SITE REF	SITE NAME AND ADDRESS	DATE PREPARED	NEXT REVIEW DATE
CLIENT / PRINCIPAL CONTRACTOR	PLANNED START	DURATION	OPERATIVES	SUPERVISING THE WORK

2 SCOPE OF WORKS

Installation of secondary steelwork: purlins, side rails, infill members and fittings, fixed from MEWPs and protected positions to the primary frame.
This document does not cover: primary frame erection (KD-RAMS-ST-001) and roof sheeting (Roofing trade).
SITE-SPECIFIC SCOPE, LOCATIONS AND LIMITATIONS

3 RISK ASSESSMENT — SCORE EACH RISK FOR THIS SITE, THEN ADD WHAT IS MISSING

The hazards and controls below are the starting point for this activity, written by a working main contractor. They are not complete for your site until a competent person has scored each risk, added the site-specific hazards, and struck out anything that does not apply. Rate risks High / Medium / Low before and after controls.

1. Falls during connection work at height
Controls: MEWPs as the default work position for connections; nets or hard barriers where the scheme provides; harnesses to rated anchors when outside protected positions — rescue plan live before anyone clips on; no walking bare steel.
At risk: Erectors

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

2. Steel lifts — falling members and trapped hands
Controls: Every lift under the lift plan and permit; tag lines to control members; hands clear of bearing points as members land — podging, not fingers; exclusion below the lift path; shackles and slings within examination dates.
At risk: Erectors, those below

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

3. Manual handling of boards, materials and components
Controls: Mechanical aids first — trolleys, board lifters, hoists. Two-person lifts for boards and long components; order materials in manageable sizes; plan storage close to the workface; keep carrying routes clear and lit.
At risk: Operatives

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

4. Hand-arm vibration from power tools
Controls: Select low-vibration tools, keep cutting edges sharp, rotate operatives to keep exposure below the action value, and record trigger time where the assessment requires it.
At risk: Operatives

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

5. Noise from cutting, fixing and plant
Controls: Select quieter methods and tools where practicable; hearing protection in designated zones and for noisy operations; agree noisy-works windows with the occupier in occupied buildings.
At risk: Operatives, others in the area

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

6. Slips, trips and housekeeping
Controls: Keep the workface clear, remove waste and offcuts as they are created, route leads at high level or under mats, and maintain task lighting.
At risk: Everyone in the work area

INITIAL (H/M/L)	RESIDUAL (H/M/L)	SITE-SPECIFIC ADDITIONAL CONTROLS, OR N/A	ACTION OWNER	BY WHEN

Site-specific hazards not listed above — every site has at least one:

SECONDARY STEELWORK AND INFILL MEMBERS

ACTIVITY RAMS — ADAPT TO SITE BEFORE USE

continued

KD-RAMS-ST-002 Rev A0

HAZARD	WHO IS AT RISK	CONTROLS	INITIAL HI...	RESIDUAL...	ACTION OWNER	BY WHEN

4 METHOD — SEQUENCE OF WORK

- 01 Confirm the primary frame is stable and signed off for secondary fixing.
- 02 Distribute members by machine; small members lifted with gin wheels or MEWP racks per their rating.
- 03 Fix from MEWPs; two-point support before releasing any member.
- 04 Complete connections progressively; no members left loosely landed.
- 05 Clear fixings and offcuts; magnetic sweep below the work area.
- SITE-SPECIFIC AMENDMENTS TO THE SEQUENCE

5 PLANT, EQUIPMENT AND MATERIALS

- MEWPs
- Gin wheel (rated)
- Impact drivers
- Magnetic sweeper
- INSPECTION / THOROUGH EXAMINATION REFS
- COSHH ASSESSMENT REFS

6 PPE — THE LAST LINE OF CONTROL, NOT THE FIRST

- Head protection
- Safety footwear
- High visibility
- Gloves — task-rated
- Eye protection
- Hearing protection
- RPE TYPE, FACE-FIT STATUS, AND ANY OTHER PPE REQUIRED

7 PERMITS REQUIRED BEFORE THIS WORK STARTS

A permit authorises this work in that place, on that day. It extends the safe system of work in this document — it does not replace it (HSE HSG250). The site issues the permit; record its number before work starts.

KD-PTW-WH-006 — Work at Height Permit
Where the site requires a permit.

PERMIT NUMBER

8 EMERGENCY ARRANGEMENTS — COMPLETE FOR THIS SITE

FIRST AIDER AND LOCATION	NEAREST A&E	ASSEMBLY POINT
HOW THE ALARM IS RAISED	EMERGENCY ACCESS FOR THIS WORK AREA	SPILL / ENVIRONMENTAL RESPONSE

9 BRIEFING RECORD — EVERYONE WORKING UNDER THIS RAMS SIGNS BEFORE STARTING

By signing you confirm the contents of this RAMS have been explained to you, you understand the hazards and controls, and you will work to the sequence stated. Tell the supervisor if the work or the site does not match this document — work stops until it does.

NAME	COMPANY	SIGNATURE	DATE

NAME	COMPANY	SIGNATURE	DATE

10 PREPARED AND ACCEPTED

Prepared / adapted for this site by — I confirm I have adapted this document to the site, scored the risks, and that it describes how the work will actually be done.

PRINTED NAME	ROLE / COMPETENCE	COMPANY	SIGNATURE	DATE	TIME

Accepted for the site by — principal contractor or site manager review.

PRINTED NAME	ROLE	COMPANY	SIGNATURE	DATE	TIME

Review this RAMS if the work, the site or the law changes, and at least before each new phase of the works. Flatten the completed PDF before filing so the record cannot be silently edited.

R REVISION HISTORY

Every revision of this document, and every review that found nothing to change. The revision on the front of this sheet is the one you are holding — check kubitdocs.com for the current one before use.

Rev	Date	Class	What changed	Authorised by
D0	2026-08-09	first-issue	First issue.	— not yet approved —
D1	2026-08-10	material	BS 5975 recited to the 2024 parts; COSHH 2002 added for welding fume, coatings and solvents. Legislation position reviewed against Product Legislation Register KD-REG-01 Rev R01.3 and the August 2026 horizon scan; cutoff moved to 10 August 2026.	— not yet approved —
A0	2026-08-27	review	Approved for issue by the author. Content unchanged from D1; the draft status strip is removed. No independent third-party review has been carried out.	Author — director, UK principal contractor, SMSTS. Not an independent review.

Class: first-issue · material (the law, a control, a field or the scope changed — past buyers are notified) · editorial (wording or layout only) · review (checked, nothing changed) · withdrawal. Revision prefix D = draft, not approved and not for sale; A = approved for issue by the person named, on the date shown.